

Emergency Stop Switches (Unibody/Illuminated) XA/XW 16mm and 22mm Series



# Short Body E-stop compliant with ISO13850

**Emergency stop switches to ensure safety** and functionality





## COMPACT AND STANDARDS-COMPLIANT SAFETY DEVICES

Emergency stop (E-stop) switches are a fundamental safety element for all types of automation, but compact equipment sizes and increasing regulatory requirements are challenging designers to find better ways of incorporating E-stops.

The IDEC XA/XW short-body E-stops address this, featuring a minimal installation footprint and meeting the requirements of ISO13850:2015 by illuminating the cap in red when the E-stop is functional (Active) to be used in an emergency situation, and turning white when the E-stop is not-functional (Inactive).

With additional safety and durability features, designers now have more choices to ensure standards-compliant safety in industrial applications.



· XA series (illuminated switch) button color: white/red


## **Features**

## Shortest depth in the IDEC X-Series lineup

Panel depth

- •12.6mm (solder terminal)
- •17.0mm (solder/tab #110 terminal)


Designed with the shortest body among multiple generations of IDEC emergency stop switches, this E-stop helps users save space behind the panel for their application.



## Unibody structure with 1NO-2NC contacts

Compact unibody structure with 3-terminal configuration suitable for a wide range of applications in limited space.


One contact (blue) can be used as a lamp terminal or as a NO contact for monitoring.



## Status indicator and escape structure

The indicator (green area) visible from the side enables the user to check the operating status of the switch at a glance.

Also, an escape structure prevents foreign objects from being caught during operation, ensuring a smooth activation of the E-stop in an emergency situation.





## Certified for outdoor use

XA/XW series E-stops are UL type 4X certified, making them the ideal E-stops for use in wet, windy, and snowy environments.\*


\*Not certified for use in all outdoor environments.




## Safer E-stop with reverse energy structure

## 3rd generation (reverse energy structure)

The energy level of the new emergency stop switch



Main contacts (NC) are always inclined to turn off (safe)



## Emergency stop function on portable operator control stations

With the growing advancements in technology, users have been demanding more convenient and efficient options such as using detachable cables that allow a single teaching pendant to be used with multiple robots or eliminating the need for wiring altogether. However, safety remains a crucial aspect that must be considered with utmost care. Therefore, the requirements for detachable and wireless operator control stations have been updated in this revision to ensure maximum safety and reliability.

## IS013850: 2015


## 4.3.8.-


When emergency stop devices are installed on detachable or cableless operator control stations (e.g. pluggable portable teaching pendants), at least one emergency stop device shall be permanently available (e.g. in a fixed position) on the machine.

In addition, at least one of the following measures shall be applied to avoid confusion between active and inactive emergency stop devices:

- device colour changing through illumination of the active emergency stop device;
- automatic (self-actuating) covering of inactive emergency stop devices; where this is not practicable, manually-applied covering may be used, provided that the cover remains attached to the operator control stations;
- provision of proper storage for detached or cableless operator control stations.

The instructions for use of the machine shall state, which measure has been applied in order to avoid confusion between active or inactive emergency stop device(s). The correct operation of this measure shall be explained.





## Intended actuation

## Recommended actuators and nameplates

To ensure quick and effective response in case of an emergency, it is crucial to optimize the operability and visibility of the emergency stop switch. The switch should be easily accessible and actuated with intent and without any hesitation.

Therefore, the following safety requirements are included.

## IS013850:2015

## 4.1.1.2-

The emergency stop function must be available and operable at all times.

## 4.3.6

The actuator of the emergency stop device shall be coloured RED. As far as a background exists behind the actuator and as far as it is practicable, the background shall be coloured YELLOW.

## 4.3.7

Neither the actuator nor the background should be labelled with text or symbols.

When it is necessary to identify the direction of unlatching of the actuator (button) then this identification shall have the same or nearly the same colour as the actuator.








Unlatching (reset side) color is the same color as the body (red)

## Intended resetting

## Importance of human intention in resetting

In emergency situations, an emergency stop switch requires an intentional action to be triggered. As such, it is also essential to consider the intended action required to reset the emergency stop switch as part of the safety requirements.

## Resetting the switch




Pull to reset

Turn to reset

## IS013850:2015

4.1.1.2-

The emergency stop function shall be reset by intentional human action. Resetting of the emergency stop function shall be operated by disengagement of an emergency stop device.



Emergency stop switches are vital safety components used across various industries to prevent accidents and ensure worker safety.

The new compact and short-body design XA/XW series offers a wider range of applications, making it a versatile and reliable solution for emergency stop needs.

## Portable pendants and robot controllers



# Low profile panels and small transport equipment




# Outdoor facilities with high temperatures (Operating temperature up to +70°C)\*



\*Non-illuminated type only

# Remote control box for use in environments exposed to rain



## ø16 XA / ø22 XW Series

## Emergency stop switches (unibody/illuminated)

The new addition to the XA/XW series features a reverse energy structure with illuminated or 1NO-2NC contact types available. These have a compact and unibody design with a panel depth of 12.6mm.


- Illuminated or 1NO-2NC contact types
- Two reset operations (Pushlock pull or turn reset)
- Reverse energy structure
- Safety lock mechanism (IEC60947-5-5: 6.2)
- Direct opening action mechanism (IEC60947-5-5: 5.2, IEC60947-5-1 annex K.)
- Protection degree IP65, IP67, (IEC60529) and IP69K (ISO20653)
- Indicator and escape structure











## **Contact ratings**

<u> </u>							
Rated insulation voltage			Non-illuminated	250V			
(Ui)		Illuminated	23UV				
Rated current (Ith)		Non-illuminated 5A					
haleu cu	rrent (iui	)	Illuminated		3A		
Rated op	erating v	oltage (Ue	e)	30V	125V	250V	
AC		AC	Resistive load (AC-12)	_	3A	1.5A	
	Main contact		Inductive load (AC-15)	_	1.5A	1.5A	
Rated			Resistive load (DC-12)	2A	0.4A	0.2A	
operating		DC	Inductive load (DC-13)	1A	0.22A	0.1A	
current		AC	Resistive load (AC-12)	_	1.2A	0.6A	
(*1) Monitor		50/60Hz	Inductive load (AC-15)	_	0.6A	0.3A	
	contact	t DC	Resistive load (DC-12)	2A	0.4A	0.2A	
		DC	Inductive load (DC-13)	1A	0.22A	0.1A	
Contact material				Gold on si	lver, crossb	ar contacts	

- Minimum applicable load (reference value) = 5V AC/DC, 1mA (Applicable range may vary with operating conditions and load types.)
- Operational current represents the classification by making and breaking current (IEC) 60947-5-1)
- \*1) UL recognized ratings: Pilot Duty AC 1.5A / 250V

Pilot Duty DC 1A/30V Maximum ambient air temperature 60°C

TÜV / CCC certified ratings: AC-15 1.5A / 250V, DC-13 1A / 30V

## **Performance Specifications**

Туре		XA	XW	
Applicable standards		IEC 60947-1, EN 60947-1, JIS C 8201-1 IEC 60947-5-1, EN 60947-5-1, JIS C 8201-5-1, IEC60947-5-5 (*2), EN60947-5-5 (*2), JIS C 8201-5-5 (*2) UL60947-5-5(*2), UL991(*2), NFPA79 (*2), ISO13850 (*3), UL508, CSA C 22.2 No. 14, GB/T14048.5		
	Operating temperature	Non-illuminated:-25 to	+70°C (no freezing)	
Standard	operating temperature	Illuminated: -25 to +5	5°C (no freezing)	
	Operating humidity	30 to 85%RH (no cond	ensation)	
conditions	Storage temperature	Non-illuminated: -45 to	o +80°C (no freezing)	
	Storage temperature	Illuminated: -30 to +70°C (no freezing)		
Operatino	g force	Pushlock: 20N Pull reset:12N Turn reset: 0.2N·m		
	force required for ening action	50N		
	operator stroke for direct opening action	3mm		
Maximun	n operator stroke	4.1mm		
Contact r	esistance	50mΩ max. (initial value)		
Insulation	n resistance	100MΩ min. (500V DC megger)		
Overvolta	ige category	II		
Impulse v	withstand voltage	2.5kV		
Degree o	f pollution	Panel front:3, Panel back: 2		

<sup>\*2)</sup> Products other than those with red button specifications are excluded from the button color requirements of the relevant standard. Y (yellow) cannot be used as an emergency stop switch.



## **Illumination rating**

Rated voltage	Coil voltage range	Rated current	
24V AC/DC	24V AC/DC ±10%	Typ.10mA	

Туре	XA	XW		
Operation frequency	900 operations per hour			
LED life (*4)	60,000 hours (Ta = 25°C, 45%RH) (The total illumination life in which the illuminance maintains a minimum of 50% of the initial value.)			
Shock resistance	Operating extremes: 150m Damage limits: 1000m/s <sup>2</sup>	/s²		
Vibration resistance	Operating extremes: 10 to 0.35mm, acceleration 50 r Damage limits: 10 to 500H acceleration 50m/s <sup>2</sup>	n/s²		
Durability	Mechanical: 250,000 times min. Electrical: 100,000 times min. 250,000 times min. (24V AC/DC, 100mA)			
Degree of Protection (*5)	Panel front: IP65, IP67, IP6	9K, UL Type 4X		
Impact protection	Equivalent to IK06, 07 *No	damages		
Short-circuit protection	250V/10A fuse (Type aM IEC60269-1/IEC6	60269-2)		
Conditional short-circuit current	100A			
Terminal style	Solder terminal Solder/tab #110 terminal			
Recommended tightening torque of locking ring	0.8 to 0.9N·m 1.8 to 2N·m			
Connectable wire	1.25mm² max. (AWG16 max.)			
Terminal soldering conditions	310 to 350°C, within 3 seconds			
Weight (approx.)	Approx. 15g Approx. 17g			
5) The protective structure is based on the test conditions of IEC60529, ISO20653, and JIS				

C 0920. This is not guaranteed for all operating environments. The specification values for the protective structure are for products that have been installed.

<sup>\*3)</sup> Illuminated white button should be used with red illumination in accordance with IS013850.

<sup>\*4)</sup> Not a guaranteed value. The actual life depends on operating environments and

## **Emergency Stop Switches**

## ø16 XA pushlock pull or turn reset switch (non-illuminated)

Quantity: 1

Shape	Part No.	art No. Contact		Button color	
	XA1E-BV3SG01	1NC	Solder terminal		
	XA1E-BV3SG01T	- INC	Solder/tab #110 terminal	Red Rright red	
	XA1E-BV3SG02	2NC	Solder terminal		
	XA1E-BV3SG02T	ZNO	Solder/tab #110 terminal		
	XA1E-BV3SG12	1NO 0NO	Solder terminal		
	XA1E-BV3SG12T	1NO-2NC	Solder/tab #110 terminal		

- · Color code: R (red), RH (bright red)
- Push lock pull or turn reset switches are locked when pressed, and reset when pulled or turned clockwise.

## ø22 XW pushlock pull or turn reset switch (non-illuminated)

Quantity: 1

Shape	Part No.	Contact	Terminal style	Button color	
	XW1E-BV3SG01	- 1NC	Solder terminal		
	XW1E-BV3SG01T		Solder/tab #110 terminal		
	XW1E-BV3SG02		Solder terminal	Dod	
	XW1E-BV3SG02T	2NC	Solder/tab #110 terminal	Red Bright red	
	XW1E-BV3SG12	1NO ONO	Solder terminal		
	XW1E-BV3SG12T	1NO-2NC	Solder/tab #110 terminal		

- · Color code: R (red), RH (bright red)
- Pushlock pull or turn reset switches are locked when pressed, and reset when pulled or turned clockwise.

## ø16 XA pushlock pull or turn reset switch (illuminated)

Quantity: 1

Shape	Part No.	Contact	Terminal style	Button color	Illuminated color
	XA1E-LV3SG02Q4R	2NC	Solder terminal	Dod	Dad
			Solder/tab #110 terminal	Red	Red
	XA1E-LV3SG02Q4WR	ana	Solder terminal		Dod
	XA1E-LV3SG02Q4TWR 2NC		Solder/tab #110 terminal		Red

## ø22 XW pushlock pull or turn reset switch (illuminated)

Quantity: 1

Shape	Part No.	Contact	Terminal style	Button color	Illuminated color
	XW1E-LV3SG02Q4R	ONC	Solder terminal	Dod	D. d
	XW1E-LV3SG02Q4TR		Solder/tab #110 terminal	Red	Red
	XW1E-LV3SG02Q4WR	ONG	Solder terminal	- White	Dod
	XW1E-LV3SG02Q4TWR	2NC	Solder/tab #110 terminal		Red

- When using white button color, make sure to use the switch as an active state when illuminated.
- Pushlock pull or turn reset switches are locked when pressed, and reset when pulled or turned clockwise.

## Accessories


Name / Shape	Part No.	Specification	Ordering No.	Quantity	Remarks
Locking ring wrench	MT-001	Metal (brass, nickel plated)	MT-001	1	For XA series. Used to tighten the locking ring when mounting the unit to the panel.
Locking ring	XA9Z-LNW	Polyamide resin (White)	XA9Z-LNW	1 (10 pcs)	For XA series
Locking ring wrench	MW9Z-T1	Metal (Brass)	MW9Z-T1	1	For XW series. Used to tighten the locking ring when mounting the unit to the panel.
Locking ring	XW9Z-LNW	Polyamide resin (White)	XW9Z-LNWPN	1 (5 pcs)	For XW series

**Dimensions** All dimensions in mm.

ø16 XA pushlock pull or turn reset switch (illuminated or non-illuminated)

# Solder terminal Solder/tab #110 terminal Panel thickness 1NO, 2NC: 0.8 to 3.7mm 1NO-1NC, 1NO-2NC: 0.8 to 3.7mm (insulated panel) 0.8 to 3.0mm (conductor panel) Panel thickness 1NO, 2N: 0.8 to 3.7mm 1NO-1NC, 1NO-2NC: 0.8 to 3.7mm (insulated panel) 0.8 to 3.0mm (conductor panel)

ø22 XA pushlock pull or turn reset switch (illuminated or non-illuminated)



Panel cut-out All dimensions in mm.

ø22 XW pushlock pull or turn reset switch

(illuminated or non-illuminated)

ø16 XA pushlock pull or turn reset switch (illuminated or non-illuminated)





## Terminal arrangement (BOTTOM VIEW)


# 1NC contact T0P

Non-illuminated

2NC contact T0P 1NC: Terminals on left 2NC: Terminals on right







## **Safety Precautions**

- Turn off the power to the product before starting installation, removal, wiring, maintenance, and inspection of the products. Failure to turn power off may cause electrical shock or fire.
- Use wires of the proper size to meet the voltage and current requirements. Incorrect wiring causes overheating, resulting in a possible fire hazard. Provide appropriate protection against electric shock. Failure to turn power off may cause electrical shock or fire.

## Instructions


## Panel mounting

## Notes for panel mounting

Do not tighten with excessive force using tools such as pliers. Otherwise the locking ring may be damaged.


#### XA series

Remove the locking ring from the operator and check that the rubber gasket is in place. Insert the operator from panel front into the panel hole. Install the locking ring with the recommended tightening torque by aligning the protrusion A of the operator with the panel hole groove. Using the locking ring wrench MT-001, tighten the locking ring to a torque of 0.8 to 0.9N·m.




#### X Series

Remove the locking ring from the operator and insert the operator from panel front into the panel hole. Install the locking ring with the recommended tightening torque by aligning the protrusion B of the operator with the panel hole groove. Using the locking ring wrench MW9Z-T1, tighten the locking ring to a torque of 1.8 to 2.0N·m.



## Wiring (Notes for solder terminal)

- The applicable wire size is 1.25mm² maximum. The wires should be soldered through the holes in the terminals.
- 2) Solder the terminals using a soldering iron at 310 to 350°C for within 3 seconds. Do not use flow or dip soldering. (Sn-Ag-Cu type lead-free solder is recommended.) When soldering, make sure to solder as far away as possible from the plastic part of the switch body. Do not apply external force such as bending the terminals or pulling the wires. Check the operation using the actual load.
- Use a non-corrosive rosin-based flux. To prevent the flux from entering the switch while soldering, face the terminals downward.



- 4) Because the terminal spacing is narrow, use protective tubes or heat shrinkable tubes to avoid burning the wire sheath or short circuit.
- Apply force on the terminals in the vertical direction to the panel only, otherwise the terminals will be damaged.

## Wiring (solder/tab #110 terminal)

- 1) Use quick connect #110 and 0.5mm tab thickness.
- 2) To prevent short-circuit between different poles, use protective tubes or heat shrink tubes.
- Apply force on the terminals in the vertical direction to the panel only, otherwise the terminals will be damaged.

## Contact chatter/bounce

Contact chatter/bounce may occur when the main contact (NC contact) is reset by pulling or turning or when the monitor contact (NO contact) is pressed. Take countermeasures to prevent chatter/bounce. (Reference value: 20ms)

Also, do not apply external shock to the switch as chatter may occur.

## **LED Illuminated Switches**

- Illumination colors and illuminance may vary depending on the LED element and each product.
- An LED lamp is built into the contact block and cannot be replaced.

#### Notes

- Do not expose the switch to excessive shock and vibration, otherwise the switch may be deformed or damaged, causing malfunction or operation failure.
- Be sure to observe the operating ambient temperature. Ambient operating temperature is the temperature surrounding the product. Check the ambient temperature when using the product. Conditions exceeding the specifications may cause the internal temperature to rise, resulting in failure.
- Do not disassemble, repair, or modify the power supplies.
- The color of the handle may vary on the production lot.
- The resin may discolor if left in a high temperature environment.
- . Do not install in the following environment
- Where this product is exposed to high-pressure water. (Exceeding specifications equivalent to IEC60529 protection classes IPX5, IPX7, and IPX9K)
- (2) Where dust (locations exceeding the specifications equivalent to IEC60529 protection class IP6X)
- (3) Where safety and reliability may be impaired by corrosive, volatile, flammable or chemicals gases, etc.
- (4) Where strong magnetic fields or strong electric fields are generated.
- (5) Where flammable substances are generated or exist.
- (6)Locations where condensation or icing may occur, such as inside freezers, air conditioner vents, etc. (When using the product in the above locations, take measures to prevent condensation or icing.)
- (9) Where ozone, radiation, or ultraviolet rays may impair safety or reliability.

Be sure to read the instruction manual carefully before performing installation, wiring, or maintenance work.

For details on mounting, wiring, and maintenance, see the instruction manual from the URL below.

URL: https://product.idec.com/?product=XA1E-XW1E



## **Ordering Terms and Conditions**

Thank you for using IDEC Products.

By purchasing products listed in our catalogs, datasheets, and the like (hereinafter referred to as "Catalogs") you agree to be bound by these terms and conditions. Please read and agree to the terms and conditions before placing your order.

## 1. Notes on contents of Catalogs

- (1) Rated values, performance values, and specification values of IDEC products listed in this Catalog are values acquired under respective conditions in independent testing, and do not guarantee values gained in combined conditions.
  - Also, durability varies depending on the usage environment and usage conditions.
- (2) Reference data and reference values listed in Catalogs are for reference purposes only, and do not guarantee that the product will always operate appropriately in that range.
- (3) The specifications / appearance and accessories of IDEC products listed in Catalogs are subject to change or termination of sales without notice, for improvement or other reasons.
- (4) The content of Catalogs is subject to change without notice.

## 2. Note on applications

- If using IDEC products in combination with other products, confirm the applicable laws / regulations and standards.
  - Also, confirm that IDEC products are compatible with your systems, machines, devices, and the like by using under the actual conditions. IDEC shall bear no liability whatsoever regarding the compatibility with IDEC products.
- (2) The usage examples and application examples listed in Catalogs are for reference purposes only. Therefore, when introducing a product, confirm the performance and safety of the instruments, devices, and the like before use. Furthermore, regarding these examples, IDEC does not grant license to use IDEC products to you, and IDEC offers no warranties regarding the ownership of intellectual property rights or noninfringement upon the intellectual property rights of third parties.
- (3) When using IDEC products, be cautious when implementing the following.
  - Use of IDEC products with sufficient allowance for rating and performance
  - Safety design, including redundant design and malfunction prevention design that prevents other danger and damage even in the event that an IDEC product fails
  - Wiring and installation that ensures the IDEC product used in your system, machine, device, or the like can perform and function according to its specifications
- (4) Continuing to use an IDEC product even after the performance has deteriorated can result in abnormal heat, smoke, fires, and the like due to insulation deterioration or the like. Perform periodic maintenance for IDEC products and the systems, machines, devices, and the like in which they are used.
- (5) IDEC products are developed and manufactured as general-purpose products for general industrial products. They are not intended for use in the following applications, and in the event that you use an IDEC product for these applications, unless otherwise agreed upon between you and IDEC, IDEC shall provide no guarantees whatsoever regarding IDEC products.
  - i. Use in applications that require a high degree of safety, including nuclear power control equipment, transportation equipment (railroads / airplanes / ships / vehicles / vehicle instruments, etc.), equipment for use in outer space, elevating equipment, medical instruments, safety devices, or any other equipment, instruments, or the like that could endanger life or human health
  - Use in applications that require a high degree of reliability, such as provision systems for gas / waterworks / electricity, etc., systems that operate continuously for 24 hours, and settlement systems
  - iii. Use in applications where the product may be handled or used deviating from the specifications or conditions / environment listed in the Catalogs, such as equipment used outdoors or applications

in environments subject to chemical pollution or electromagnetic interference

If you would like to use IDEC products in the above applications, be sure to consult with an IDEC sales representative.

## 3. Inspections

We ask that you implement inspections for IDEC products you purchase without delay, as well as thoroughly keep in mind management/maintenance regarding handling of the product before and during the inspection.

## 4. Warranty

(1) Warranty period

The warranty period for IDEC products shall be one (1) year after purchase or delivery to the specified location. However, this shall not apply in cases where there is a different specification in the Catalogs or there is another agreement in place between you and IDEC.

#### (2) Warranty scope

Should a failure occur in an IDEC product during the above warranty period for reasons attributable to IDEC, then IDEC shall replace or repair that product, free of charge, at the purchase location / delivery location of the product, or an IDEC service base. However, failures caused by the following reasons shall be deemed outside the scope of this warranty.

- The product was handled or used deviating from the conditions / environment listed in the Catalogs
- ii. The failure was caused by reasons other than an IDEC product
- iii. Modification or repair was performed by a party other than IDEC
- iv. The failure was caused by a software program of a party other than IDEC
- v. The product was used outside of its original purpose
- Replacement of maintenance parts, installation of accessories, or the like was not performed properly in accordance with the user's manual and Catalogs
- vii. The failure could not have been predicted with the scientific and technical standards at the time when the product was shipped from IDFC
- viii. The failure was due to other causes not attributable to IDEC (including cases of force majeure such as natural disasters and other disasters)

Furthermore, the warranty described here refers to a warranty on the IDEC product as a unit, and damages induced by the failure of an IDEC product are excluded from this warranty.

## 5. Limitation of liability

The warranty listed in this Agreement is the full and complete warranty for IDEC products, and IDEC shall bear no liability whatsoever regarding special damages, indirect damages, incidental damages, or passive damages that occurred due to an IDEC product.

## 6. Service scope

The prices of IDEC products do not include the cost of services, such as dispatching technicians. Therefore, separate fees are required in the following cases.

- Instructions for installation / adjustment and accompaniment at test operation (including creating application software and testing operation, etc.)
- (2) Maintenance inspections, adjustments, and repairs
- (3) Technical instructions and technical training
- (4) Product tests or inspections specified by you

The above content assumes transactions and usage within your region. Please consult with an IDEC sales representative regarding transactions and usage outside of your region. Also, IDEC provides no guarantees whatsoever regarding IDEC products sold outside your region.





22 FACTORIES



75 YEARS OF EXPERIENCE



(S) 3,900 EMPLOYEES WORLDWIDE



100 000 + REFERENCES

## **EMEA SALES & CUSTOMER SUPPORT**

Contact our safety specialists at eu.support@idec.com

## **BENELUX**

Belgicastraat 7/1 1930 ZAVENTEM Belgium BEL: (+32) 27 25 05 00 NL: (+31) (70) 799 91 51 be.sales@apem.com

## FRANCE

55, avenue Edouard Herriot 82303 CAUSSADE Cedex (+33) 5 63 93 14 98 fr.commercial@apem.com

## **GERMANY**

Gewerbehof Giesing Paulsdorfferstr. 34, 2. OG D-81549 MUNICH MUNICH: (+49) 89 45 99 11 0 HAMBURG: (+49) 40 253054 0 de.info@apem.com

## **ITALY**

Via Savigliano 6/B 12062 CHERASCO (Fraz. Roreto di Cherasco) Tel: (+39) 0172 74 31 70 apem.italia@apem.com

## **SWEDEN**

Torshamnsgatan 39 S-16440 KISTA (+46) 8 626 38 00 se.info@apem.com

## UNITED KINGDOM

Drakes Drive LONG CRENDON, Bucks HP18 9BA England (+44) 1 844 202400 uk.sales@apem.com

eu.idec.com

in Follow us on LinkedIn Follow us on Youtube

